



NATURAL GAS PIPING ISOMETRIC
NO SCALE

- NOTES:
- 1 COORDINATE HEIGHT OR ROUGH IN FOR NATURAL GAS PIPING WITH EQUIPMENT MANUFACTURER.
 - 2 SHUT-OFF VALUES SHALL BE LISTED FOR NATURAL GAS SERVICE.
 - 3 ABOVEGROUND PIPING SHALL BE GALVANIZED STEEL PIPING. UNDERGROUND PIPING SHALL BE POLYETHYLENE.
 - 4 PIPING SIZED PER FBC TABLES 402.4(2) & 402.4(19).

4" SANITARY. SEE CIVIL DRAWINGS FOR CONTINUATION. 27 FU.

07/17/15
CITY COMMENTS

Designed By:
Drawn By:
Date: 2.6.15
Job No. 1420